

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20242369
Address: 1617 SW ARBORWAY TER, LEES SUMMIT, MO 64082
Inspected On: Monday, December 16, 2024
Inspected By: Development Center
Expiration Date:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Ready for Temp CO	Monday, December 16, 2024

Corrective Action Required:

1	Misc	-address to be properly illuminated -final grade and sod -bring water meter pit to grade (ensure 14"-18" from top of meter to well lid ring) -identify sewer tracer wire
---	------	---

Comments: