

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240929
Address: 2319 SW SERENA PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Monday, December 16, 2024

Corrective Action Required:

1	Miscellaneous Correction	-Fb basement hallway wall from ceiling space; fb basement bedroom 2&3 and bathroom walls from ceiling and soffit spaces; provide vertical fire blocking at max 10 ft for bedroom 3 -Provide return air path to basement bedroom 2 (remove blocking) and seal plumbing penetration in this joist space -Reinstall electrical in basement
---	--------------------------	---

**OK TO INSULATE

Comments: