

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241045

Address: 1433 SW WINTHROP TER, LEES SUMMIT, MO 64081
1431 SW WINTHROP TER, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Bobby Richest	Partial	Thursday, December 12, 2024

Informational:

1 Misc

12-12-24 BR Sidewalk is formed up with aggregate places and compacted ready for concrete.

12-16-24 BR Sidewalk was poured to LS specification. Prior to inspection the existing sidewalk that is adjacent to new sidewalk is damage to existing sidewalk and will need to be repaired.

Comments: