

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20232899
Address: 2840 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|----------------------------------|---------------|----------|----------------------------|
| Sanitary Sewer - Air Test | Bobby Richest | Passed | Tuesday, December 17, 2024 |

Informational:
1 Misc 12/17/24 Tuesday JMJ (Selby Construction)
Air test passed from MH-A10 to A9, A9 to A8, A8 to A7.

Comments: