

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20244364  
Address: 1050 SW FIORD DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Shawn Hoffman	Failed	Tuesday, December 17, 2024

Corrective Action Required:

1 Misc

PORTAL FAME  
Garage portal approved  
Entry roof , provide hangers on rafters garage side

Corrective Action Required:

2 Misc

- Upload truss repair to B3 in garage near attic access
- Upload truss repair to A13 above laundry
- In bedroom 3 plans call for 2 king studs each side of window to carry girder truss load
- Install window in basement
- 3 studs minimum at exterior wall corners at basement South West corner

**Comments:**