

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20243494
Address: 2774 SW 11TH TER, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Tuesday, December 17, 2024

Corrective Action Required:

2	Misc	2774
---	------	------

- Anchor bolts garage Missing at portal frame missing a 2x2" washer
- Secure CSST at fire place within 12" of appliance
- At main floor, wall at stairs is to be 2x6" to support I-beam
- Missing column at stairs main floor
- Fire block top of HVAC chase upstairs laundry
- Support dryer vent
- Repair floor primary bathroom

Comments: