

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242428
Address: 3116 SW SUMMIT VIEW TRL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Dustin Agcopra	Partial	Tuesday, December 17, 2024

Corrective Action Required:

1	DCM2 ESC DEFICIENT INSTALLATION	DEFICIENT EROSION CONTROL INSTALLATION. NO FURTHER INSPECTIONS UNTIL ADEQUATE EROSION CONTROL PROVIDED.
---	---------------------------------------	---

Repair down silt fence
Maintain overgrown vegetation

10-14-24 Dustin A, Still not fixed
10-17-24 Dustin A, not corrected and there is gravel in rd
10-30-24 Dustin A, Corrected.

Corrective Action Required:

2	DCM3 ESC REQUIRED 2 DAY	12-12-24 Dustin A, Silt fence is down EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS. 12-17-24 Dustin A, Silt fence has been repaired
---	----------------------------	---

Comments: