

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20234376
Address: 600 NE MAGUIRE BLVD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Piers/Caissons Inspection - Commercial	Khanh Nguyen	Failed	Tuesday, December 17, 2024

Corrective Action Required:

1	Misc	Light pole piers: -Equally space the #6 vertical rebars -Remove loose soil from pier holes -Expose all grounding rod connections -Raceway must be min 18" below grade
---	------	---

****All underground raceways are subjected to inspection. Raceway underneath parking lot and driveway shall be min 24" below surface; min 18" below grass**

Comments: