CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20244575

Address: 2721 SW 12TH ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

All Rough Inspection - Shawn Hoffman Failed Tuesday, December

Residential 17, 2024

Corrective Action Required:

3 Misc

- Strap top plate of load bearing wall where DWV has over bored plate garage/bathroom
- Fire block top plate of HVAC chase in pantry $% \left(\mathbf{r}\right) =\left(\mathbf{r}\right)$
- Fire block top of chase at dining/ great room
- Fire block top of chase at north West corner of great room
- Fire block top of chase at north east corner of flex room
- Window at landing next to front door to be tempered
- Nail double girder truss in primary bedroom to manufacture specifications

-

Comments: