

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20226053  
Address: 1021 SE HAMBLER RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Pavement-Surface</b>	Bobby Richest	Partial	Tuesday, December 17, 2024

Informational:

1 Misc

12-16-24 BR Contractor (Blacktop Paving Maintenance) poured 4" of KCM MB A-3 on SE Hamblen Rd. turn lane section. There was no 3rd party tester for compaction on site.

12-17-24 BR Contractor (Blacktop Paving Maintenance) poured 2" KCM MB A-2 on SE Hamblen Rd turn lane section. The 3rd party tester (Geotech) is on site testing surface.

**Comments:**