CITY OF LEE'S SUMMIT

Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

STOP WORK ORDER

ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE PROSECUTED

Permit #: PRRES20242156

Address: 2760 SW 11TH ST, LEES SUMMIT, MO 64081

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection: Outcome: Date:

Erosion Control Devon Perry Failed - Stop Work Tuesday, December 17, 2024

Corrective Action Required

1 Misc - REPAIR SILT FENCE

Corrective Action Required

DAY

2 DCM3 ESC REQUIRED 2 12-13-24 Dustin A, Silt fence is down. EROSION CONTROL

REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE

WITHIN TWO BUSINESS DAYS.

12-17-24 DP. Silt fence is still not in compliance. Stop work

order issued.

Comments: