

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20231204  
Address: 2951 SE SHENANDOAH DR, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Pavement-Proof Roll</b>	Bobby Richest	Partial	Wednesday, January 03, 2024

Informational:

1	Misc	1-3-24 BR Contractor performed a proof roll on 9" chemically subgrade at the 2nd entrance approach on the parking lot on building 3 which was passed to put down 6" of asphalt base
		12-17-24 BR Contractor performed a poof roll on 9" chemically subgrade on parking lot at building 3 & building 4 pass.

**Comments:**