

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20242294  
Address: 1609 SW ARBORWAY TER, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mitchell Schwarz	Ready for Temp CO	Wednesday, December 18, 2024

Corrective Action Required:

1	Misc	-final grade and sod -obtain issued lawn irrigation permit -splash blocks and sump pump discharge to extend 36" from foundation -will check water meter at Time of final grade and sod. Ensure water meter pit lid flush with grade. Ensure 14"-18" from top of meter to well lid ring -identify sewer tracer wire -seal all exterior penetrations
---	------	---

Comments: