

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20243908
Address: 3449 SE CORBIN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Kyle Beard	Failed	Wednesday, December 18, 2024

Corrective Action Required:

1	Misc	- fb rear wall vertically at max 10 ft intervals in rec room and down stairs bathroom -Strap wall top plates bored more than 50% at hallway bathroom -Protect wiring within 6 ft of attic access
---	------	--

Comments: