

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20243932  
Address: 3441 SE CORBIN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Kyle Beard	Failed	Wednesday, December 18, 2024

Corrective Action Required:

2	Miscellaneous Correction	<ul style="list-style-type: none"><li>- Seal gaps in fire blocking South east side of garage fir out</li><li>- Missing anchor bolt at sill in bathroom near owner entry</li><li>- Minimum of 3 studs required at exterior corners, north East cripple wall</li><li>- Anchor sill plate at bathroom off owner entry</li><li>- Damaged girder G1 on South end (provide engineers letter)</li><li>- Finish electrical for garage exterior light fixture</li></ul>
---	-----------------------------	--

Comments: