

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20244021
Address: 1113 SW FIORD DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Wednesday, December 18, 2024

Informational:

1	Misc	See engineer letter for LVL not upset
---	------	---------------------------------------

Corrective Action Required:

5	Misc	Fire block top of double wall at kitchen/ garage - Dining room exterior wall is a CS-PF, no straps or sheeting nail pattern completed - Anchor steel column at dining/kitchen - Provide security blocking at front door hinges side - Install HD 83 hold downs as on plans - Sister over notched stud in basement pony wall near electrical panel - Tighten anchor bolts through out basement - Missing al LUS24 truss hangers
---	------	-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Comments: