



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

Prevention Division
(816)969-1300

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20243960	Date:	December 18, 2024
Project Title:	CRAFT PUTT	Applicant:	
Location:			
840 NW BLUE PKWY, Unit:M, LEES SUMMIT, MO 64086		MARMIC FIRE & SAFETY CO INC	
Type of Work:		PO BOX 1086	
Occupancy Group:	A-2	JOPLIN, MO 64802	
Description:	CRAFT PUTT - TENANT FINISH FOR RESTAURANT WITH MINI GOLF COURSE	Primary: (417) 623-3584	
**processed as addition because of new exterior cooler			
Construction Type:	Type IIB (Unprotected)		
Map Page:			

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Craig Hill

Rejected

1. Remove horn strobes on the North patio. They are not required.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.