

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20241770
Address: 3724 SW KNOXVILLE CT, LEES SUMMIT, MO 640823722 SW KNOXVILLE CT, LEES SUMMIT, MO 64082
Inspected On: Wednesday, December 18, 2024
Inspected By: Development Center
Expiration Date: 1/17/2025 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Kyle Beard	Ready for Temp CO	Tuesday, December 17, 2024
Corrective Action Required:			
2 Miscellaneous Correction	Both	-address pending driveway & sidewalk inspection -will check water meter at time of final grade and sod ensure 14"-18" from top of meter to well lid ring -final grade and sod -splash blocks and sump pump discharge to extend 36" from foundation	
	Both passed for TCO only		

Comments: