

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20234376
Address: 600 NE MAGUIRE BLVD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	Khanh Nguyen	Failed	Thursday, December 19, 2024

Informational:
1 Misc -Secondary from transformer to bdlg-OK
Corrective Action Required:
2 Misc -All underground raceways are subjected to inspection. Raceway underneath parking lot and driveway shall be min 24" below surface; min 18" below grass

Comments: