



November 26, 2024

KC Concrete

Re: 2739 SW Heartland Rd
Lot 191, Retreat at Hook Farms
Lee's Summit, MO
Permit: PRRES20245048

Apex Engineers, Inc. observed the preparation of the suspended slab at the above-referenced address.

As city approved plans were not available the following observations were made:

The suspended slab is reinforced with #4 bars at 12" on center each way. The forms and reinforcing steel were found to be clean, well aligned, properly supported.

Notes:

- The observation was performed at 10:15 am.
- At the time of the inspection the temperature was 35°F.


This report is a visual observation and does not constitute approval by Apex Engineers, Inc. or the enforcing jurisdiction.

LIMITATIONS

The recommendations and conclusions given in this report are based on the observed conditions at the time of this site visit. The scope of our services was only to observe the installation of the slab formwork and reinforcing steel. If changes in the condition of the site occur and Apex Engineers, Inc. is not allowed the opportunity to re-evaluate the site to respond to any of these changes, our firm cannot be responsible for the effect of any of the conditions that differed from those reported herein.

Please call if Apex Engineers, Inc. can be of further assistance.

Best Regards,
Apex Engineers, Inc.


Joshua Elizondo
Field Engineer

Clayton J. Hess
Principal

