

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20244075  
Address: 2100 SE BLUE PKWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Gas Piping Inspection - Commercial</b>	Khanh Nguyen	Failed	Thursday, December 19, 2024

Corrective Action Required:

1	Misc	New 2" gas line to the boilers tested OK; however, the gas line going to the temporary boiler outside is plastic PE gas line. This temporary plastic gas line is prohibited to be installed inside (only allowed outside and underground only). This violation shall be rectified immediately
---	------	---

**Comments:**