

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20246336
Address: 3202 SW ENOCH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Thursday, December 19, 2024

Corrective Action Required:

1 Misc

-fireblock all walls to ceiling spaces and furr downs
(at top plate , top of columns, chases, soffits, sect.)

-fireblock walls horizontally every 10' from floor to ceiling (from exterior wall to fur out wall)

- frame up steel coloumn and fire block top

Comments: