

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242566
Address: 3117 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Friday, December 20, 2024

Corrective Action Required:

1	Misc	-address pending sidewalk inspection -final grade and sod -provide as graded plot plan -splash blocks and sump pump discharge to extend 36" from foundation -repair hole in garage near owners entry -all outlets in garage to be GFCI protected -address stairs at rear patio installed on wrong side -rear patio gfci not working
---	------	--

Comments: