

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20242368  
Address: 1629 SW ARBORWAY TER, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                                     | Inspector:       | Outcome:          | Date:                     |
|---|------------------|-------------------|---------------------------|
| <b>Occupancy Inspection - Codes Residential</b> | Mitchell Schwarz | Ready for Temp CO | Friday, December 20, 2024 |

Corrective Action Required:

|   |      |  |
|---|------|--|
| 1 | Misc | -final grade and sod   |
|   |      | -splash blocks and sump pump discharge to extend 36" from foundation |

**Comments:**