

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20240530  
Address: 2528 NE WOODLAND OAK CIR, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mitchell Schwarz	Ready for Temp CO	Friday, December 20, 2024

Corrective Action Required:

1	Misc	-Provide sewer tracer wire port at grade
		-Lag deck ledger board to floor rim board per code
		-Attach deck beam to each post with two 1/2" through bolts/washers/nuts or equivalent connections. Provide verification of the framing per Vista Engineering letter

**Comments:**