

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20240530
Address: 2528 NE WOODLAND OAK CIR, LEES SUMMIT, MO 64086
Inspected On: Friday, December 20, 2024
Inspected By: Development Center
Expiration Date:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Ready for Temp CO	Friday, December 20, 2024

Corrective Action Required:

1 Misc

-Provide sewer tracer wire port at grade

-Lag deck ledger board to floor rim board per code

-Attach deck beam to each post with two 1/2" through bolts/washers/nuts or equivalent connections. Provide verification of the framing per Vista Engineering letter

Comments: