

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20241886
Address: 251 NE ALURA WAY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Sediment Control (ESC) Inspection	Devon Perry	Partial	Monday, December 23, 2024

Informational:

1	Misc	10-30-24 DP. Advanced excavation installed silt sock around the perimeter of the site. They are using a water truck for dust control. No ESC issues at this time.
		12-5-24 DP. Please make sure site is dressed up and erosion control measure are in place as a DNR audit starts next week.
		12-23-24 DP. Contractor has installed straw waddles around the perimeter of the site. They are keeping up with cleanliness. They have been sweeping Colburn Rd where their trucks are crossing. The rest of the debris on Colburn is from the CIP Project. No ESC issues at this time.

Comments: