

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20244024
Address: 3203 SW ARBOR SOUND DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Dustin Agcopra	Partial	Monday, December 23, 2024

Corrective Action Required:

1	DCM3 ESC REQUIRED 2 DAY	12-16-24 Dustin A, Curb along Buckthorn needs to be cleaned where dirt was being hauled out .. EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS.
---	----------------------------	-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

12/19/24 Jamie S, Silt fence in still down. Dirt still in the road.

12-23-24 Dustin A, Erosion control is in place , must be maintained .

Comments: