

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20245976
Address: 2225 NE TOWN CENTRE BLVD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Commercial	Khanh Nguyen	Failed	Monday, December 23, 2024

Corrective Action Required:

1	Misc	-Provide two 1/2" anchors per base plate per plan -Install safety pins for all racks -Several installed racks are not shown on the plan
---	------	---

Comments: