

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20243632
Address: 1538 SW ARBOR FALLS DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Monday, December 23, 2024

Corrective Action Required:

1	Misc	-provide as graded plot plan. -final grade and sod -obtain issued lawn irrigation permit -address pending sidewalk inspection -splash blocks and sump pump discharge to extend 36" from foundation -all outlets in garage to be gfci protected or single pull receptacle and labeled -
---	------	--

Comments: