

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20243878
Address: 1543 SW ARBOR VALLEY DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Dustin Agcopra	Passed	Monday, December 23, 2024

Informational:
1 Misc 12-17-24 Dustin A, sw has been formed and compacted, slopes are in compliance . Fixed a section that Gravel was to shallow . Approved to pour
12-23-24 Dustin A, SW is poured to city specs and slopes are in compliance .
Pass

Comments: