

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20242627  
Address: 3509 SE CORBIN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Shawn Hoffman	Failed	Monday, December 23, 2024

Corrective Action Required:

1 Misc

Portal frame and front porch cover inspected only. Approved

Corrective Action Required:

4 Misc

- support soffit wider than 4' basement rec room
- Fire block top of HVAC chase
- In basement rec room
- Nail off stud packs throughout per code
- Fb around I- beam in garage foyer wall
- Fb top of chase behind shower master bathroom
- Fb too plate penetration north east corner master bedroom
- Nail off siding to code, sill plate north side and south side around line set

**Comments:**