

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20242627  
Address: 3509 SE CORBIN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Electrical Service Inspection</b>	Kyle Beard	Failed	Tuesday, December 17, 2024

Corrective Action Required:

1	Miscellaneous Correction	Bonding wire is not properly connected to the clamp at the Ufer
---	--------------------------	---

**Comments:**