

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20242210
Address: 1020 NW PRYOR RD, Unit:G, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Robb Popp	Failed	Monday, December 23, 2024

Corrective Action Required:

1	Misc	-Obtain approval from Jackson County Health Department -Breaker at P2 sec 2 to be 200 amp per plan -Provide air gap at sink drain in bar area -Urinal screen to be min 15" from centerline of urinal
---	------	---

Comments: