

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20244614  
Address: 3437 SE CORBIN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Shawn Hoffman	Failed	Monday, December 23, 2024

Corrective Action Required:

1	Misc	-Fb rec room wall from soffit
		-Provide water service shutoff within 5 ft of building entrance
		-Strap exterior wall top plates where bored more than 50%
		OK TO INSULATE

Comments: