

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242617
Address: 2743 SW HEARTLAND RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Dustin Agcopra	Partial	Monday, December 23, 2024

Corrective Action Required:

1	Miscellaneous Correction	12-18-24 DP. Driveway was formed but is saturated with water will need to be dug out or dried out before pour. Make sure to call an inspection back in. FAILED 12-23-24 Dustin A, DW has been dug out to dry conditions. Slopes and aggregate is in compliance. Approved to pour
---	--------------------------	--

Comments: