

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20243211
Address: 1542 SW ARBOR FALLS DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Ready for Temp CO	Tuesday, December 24, 2024

Corrective Action Required:

1	Misc	-ensure address is contrasting in color from backdrop -final grade and sod -water meter needs to be 14"-18" from top of meter to well lid ring(you're at 28") (meter risers must be approved by the water department) you also have 3 meter pit risers. Any conservative meter risers must be approved through water department. -splash blocks and sump pump discharge to extend 36" from foundation
---	------	--

Comments: