

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20236155
Address: 2354 SW HICKORY LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Tuesday, December 24, 2024

Corrective Action Required:

1	Misc	-will check GB bracing at time of sheet rock -fireblock furr out wall in garage (see R/A) -pan return air stud space in ceiling 2nd floor owners bath -block cantilever floor joist areas in basement.
---	------	---

Okay to insulate

Comments: