

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242325
Address: 2135 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Robb Popp	Not Ready	Tuesday, December 24, 2024

Corrective Action Required:

1	Misc	Note for all rough: -Deck posts to be full height 6x6s
---	------	---

Corrective Action Required:

2	Misc	12/24/24 -Not ready for occupancy inspection -Open electrical at front (receptacles not installed) -Address must be contrasting color to background (cannot be black on black) -Deck incomplete (No decking or railing is installed) -Address deck posts from rough in inspection -Water meter covered -Fee assessed
---	------	---

Comments: