

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20243018
Address: 1905 SW HIGHTOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Kyle Beard	Not Ready	Friday, December 27, 2024

Corrective Action Required:

1	Miscellaneous Correction	1905 SW Hightown. Occupancy Back porch steps riser height are not to code on 3/8 of an inch variance Fire block bottom of chases in garage Stair riser height from main living area to basement can not exceed 7 3/4 inches Lights in basement are not installed Secure electrical above HWT Sod, splash pads and sump pump extensions are not installed Seal all exterior penetrations House is locked and no access code is provided-not ready for inspection KBEARD
---	--------------------------	---

Comments: