

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242465
Address: 2759 SW 12TH TER, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Ready for Temp CO	Friday, December 27, 2024

Corrective Action Required:

- | | |
|---|---|
| 1 | Misc |
| | <ul style="list-style-type: none">- place sod- Provide splash pads- Sump discharge to be away 36" from foundation- Pending sidewalk inspection- Uncover water meter |

Comments: