

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20244542
Address: 3215 SW ARBORIDGE CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Not Ready	Monday, December 30, 2024

Corrective Action Required:
1 Misc PORTAL FRAME APPROVED

PORCH MISSING RIDGE SUPPORT

Corrective Action Required:
2 Misc No fire blocking done. House not ready Complete fire blocking for inspection

Comments: