

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242627
Address: 3509 SE CORBIN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Kyle Beard	Not Ready	Monday, December 30, 2024

Corrective Action Required:

1	Misc	Portal frame and front porch cover inspected only. Approved
3	Miscellaneous Correction	<ul style="list-style-type: none">- Support soffit wider than 4' basement rec room (every 4 feet on center)- Fb top of chase behind shower master bathroom- Nail off siding to code, sill plate north side and south side around line set

No improvements were made since the last inspection.

Walk your property before scheduling your inspections

Not ready for inspection
12/30/2024. KBEARD 8:15am

Comments: