

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20244614
Address: 3437 SE CORBIN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Kyle Beard	Failed	Monday, December 30, 2024

Corrective Action Required:

1	Miscellaneous Correction	Fb rec room wall from soffit around lbeam -Strap exterior wall top plates where bored more than 50% (in master bathroom)
---	--------------------------	---

OK TO INSULATE

Corrective Action Required:

2	Miscellaneous Correction	Fb rec room wall from soffit around lbeam OK TO INSULATE
---	--------------------------	---

Comments: