

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20242325  
Address: 2135 NW KILLARNEY LN, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mitchell Schwarz	Failed	Monday, December 30, 2024

Corrective Action Required:

4	Misc	-final grade and sod and sod -obtain issued lawn irrigation permit -splash blocks and sump pump discharge to extend 35" from foundation -provide adequate illumination for premise identification -uncover covered water meter ensure meter is 14"-18" from top of meter to well lid ring -complete deck guard rails and handrails -provide landing at deck stairs -provide secondary locking device for basement slider
---	------	---

Comments: