

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20235208  
Address: 2911 SE SHENANDOAH DR, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Commercial</b>	Khanh Nguyen	Partial	Monday, December 30, 2024

Corrective Action Required:

1	Misc	Footing OK to pour: -ext. footing from A/4 to A.1/2 -A/4 to L.5/5 (5/16/24-AF) -ext. footing from L.5/5 to M.9/3; complete rear footing from N to A -remaining storm shelter wall footing -4 storm shelter column pads and columns; elevator footing pad and wall -building 4 upper footing and slab by SH -remaining upper footing
---	------	--

Comments: