

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20224156  
Address: 512 NE PROMISED VIEW DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Khanh Nguyen	Partial	Monday, December 30, 2024

Corrective Action Required:

1	Misc	-Gas piping union fitting cannot be in concealed space **Make this accessible
		-Complete installing feeder to detached garage panel
		-Fb detached garage wall vertically with 3/4" sheathing or other approved material

**\*\*OK TO ROCK HOUSE**

**Comments:**