

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242325
Address: 2135 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|------------|----------|----------------------------|
| Occupancy Inspection - Codes Residential | Robb Popp | Failed | Tuesday, December 31, 2024 |

Corrective Action Required:

| | | |
|---|------|--|
| 1 | Misc | <ul style="list-style-type: none">-pay all fees-final grade and sod and sod-obtain issued lawn irrigation permit-splash blocks and sump pump discharge to extend 36" from foundation-provide adequate illumination for premise identification-uncover covered water meter ensure meter is 14"-18" from top of meter to well lid ring-Deck handrails must extend to a point directly above the lowest riser-Complete electrical being added in kitchen ceiling |
|---|------|--|

Comments: