

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20245719
Address: 2230 SW HEARTLAND CT, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|------------|----------|----------------------------|
| All Rough Inspection - Residential | Robb Popp | Failed | Tuesday, December 31, 2024 |

Corrective Action Required:

| | | |
|---|------|---|
| 1 | Misc | **PF inspection only: -2 car garage CSPF ok to cover -1 car garage shows PFH on plans-No hold downs, straps or nailing present -1st floor CSPF-provide double blocks and nail 3" oc at horizontal seam -Basement CSPF-missing anchor bolts and straps. exterior ok to cover |
|---|------|---|

Comments: