



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

Prevention Division
(816)969-1300

PLANS REVIEW CONDITIONS

Permit No: PRCOM20245730

Project Title: 1X PLASTICS

Location:

2700 NE MCBAIN DR, LEES SUMMIT, MO 64064

Type of Work:

Occupancy Group: S-1

Description: 1X PLASTICS - TENANT FINISH FOR
STORAGE AND DISTRIBUTION OF PLASTIC MATERIALS

Construction Type: Type IIB (Unprotected)

Map Page:

Date: January 02, 2025

Applicant:

FIRE ALARM SOLUTIONS

3150 MERCIER STREEET STE 520

KANSAS CITY, MO 64111

Primary: (816) 753-4660

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Craig Hill

Released for Construction

1. 2018 IFC 904.4.2- Alarm testing. Notification appliances, connections to fire alarm systems, and connections to approved supervising stations shall be tested in accordance with this section and Section 907 to verify proper operation.

Call (816)969-1300 24 hours in advance to schedule an alarm test.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.